

**MASON INDUSTRIES, Inc.***Manufacturers of Vibration Control Products*

350 Rabro Drive 2101 W. Crescent Ave., Suite D
Hauppauge, NY 11788 Anaheim, CA 92801
631/348-0282 714/535-2727
FAX 631/348-0279 FAX 714/535-5738
Info@Mason-Ind.com Info@MasonAnaheim.com

**2" (50mm) HS AND DNHS
SPRING HANGER
INSTALLATION INSTRUCTIONS****DATE: 6-21-2001****DRAWING NO.**

1. **INSTALL EQUIPMENT IN IT'S OPERATING POSITION, TEMPORARILY SUPPORTED WITH RIGGING AS REQUIRED.**
2. **ATTACH HANGER BOXES TO UPPER AND LOWER RODS.**
3. **ADJUSTMENT IS MADE BY TURNING TOP NUTS ON THE LOWER RODS THAT PASS THROUGH THE SPRINGS. TAKE 12 CLOCKWISE TURNS ON EACH HANGER NUT TO COMPRESS THE SPRINGS UNIFORMLY AND AVOIDING OVERLOADING INDIVIDUAL HANGERS. THE SAME ADJUSTMENT CAN BE MADE BY TURNING THE NUTS ON THE BOTTOM OF THE HANGER RODS IF MORE CONVENIENT. IT IS VERY IMPORTANT THAT THE HANGERS ARE ADJUSTED UNIFORMLY. REPEAT THIS PROCEDURE UNTIL THE RIGGING CAN BE REMOVED.**
4. **LEVEL EQUIPMENT BY TAKING ADDITIONAL TURNS AT THE LOW CORNER OR SIDE.**

DWN: JT**CHKD:****DATE: 6-21-2001**