



MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products

350 Rabro Drive 2101 W. Crescent Ave., Suite D
Hauppauge, NY 11788 Anaheim, CA 92801
631/348-0282 714/535-2727
FAX 631/348-0279 FAX 714/535-5738
Info@Mason-Ind.com Info@MasonAnaheim.com

1" (25mm) W30, W30N, WHS & WDNHS SPRING HANGER INSTALLATION INSTRUCTIONS

DATE: 11-22-11

DRAWING NO. A-34059

- 1. INSTALL EQUIPMENT IN ITS OPERATING POSITION, TEMPORARILY SUPPORTED WITH RIGGING AS REQUIRED.**
- 2. ATTACH HANGER BOXES TO UPPER AND LOWER WIRES.**
- 3. RIGGING MAY BE REMOVED AFTER THE UPPER AND LOWER WIRES ARE ATTACHED.**
- 4. AFTER THE SYSTEM IS AT ITS OPERATING WEIGHT, CHECK ALL HANGERS TO INSURE THERE IS A 1/4"(6mm) CLEARANCE BETWEEN THE PRECOMPRESSION PLATES AND THE UNDERSIDE OF THE HANGER BOX. IF NOT, TURN THE PRECOMPRESSION NUT AND LOWER THE PRECOMPRESSION PLATE.**
- 5. LEVEL EQUIPMENT BY REVISING THE LENGTH OF THE WIRE AT THE LOW CORNER OR SIDE OF THE LOWER WIRE ONLY.**

DWN: JT

CHKD:

DATE: 3-19-04